



## City of Nampa Waterworks Division

24 1st St S  
Nampa, ID 83651

Este informe contiene informacion muy importante sobre la calidad de su agua beber. Traduscalo o hable con alguien que lo entienda bien.

# WATER 2009 Quality Report Coventry Place

## WHERE DOES YOUR WATER COME FROM?

The Coventry drinking water supply is provided by a single ground water source (well) which draws from the Snake River Plains Aquifer.

Last year, we conducted tests for 80 contaminants and your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The City of Nampa vigilantly safeguards its water supplies and we are proud to report that this system has not violated a maximum contaminant level or any other water quality standard. No source water assessment is available. We are committed to providing you with information because informed customers are our best allies.

## HOW DO I GET MORE INFORMATION ON MY WATER?

We continually update our website with news regarding your water. It's a wonderful resource to check first. Go to [www.nampawaterdivision.org](http://www.nampawaterdivision.org) or email [water@cityofnampa.us](mailto:water@cityofnampa.us)

Call our office at **208.468.5860** or fax us at **208.465.2216**

Mail us at **24 1st St S, Nampa ID 83651**

## HEALTH INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

## TAP WATER OR BOTTLED WATER?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water:

- ◊ *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife
- ◊ *Inorganic contaminants*, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming
- ◊ *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses
- ◊ *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems
- ◊ *Radioactive contaminants*, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## WATER QUALITY DATA TABLE

The table in this report includes the following substances that may be of importance to our customers:

### LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Nampa is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### ARSENIC

While your drinking water meets the current standard for arsenic, it does contain low levels of arsenic. The standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. USEPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

### NITRATE

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short period of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

## Water Quality Data Table – 2009

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants Disinfectants & Disinfection By-Products (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)	MCLG or MRDLG	MCL, TT, or MRDL	Your Water		Range		Sample Date	Violation	Typical Source
			Low	High	Low	High			
TTHMs [Total Trihalomethanes] (ppb)	NA	80	15.8	NA	NA	2006	No	By-product of drinking water disinfection	
<b>Inorganic Contaminants</b>									
Arsenic (ppb)	0	10	7	NA	NA	2008	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes	
Fluoride (ppm)	4	4	1.83	.5	1.83	2006	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Nitrate [measured as Nitrogen] (ppm)	10	10	6.15	NA	NA	2009	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	
Nitrite [measured as Nitrogen] (ppm)	1	1	.03	NA	NA	2005	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.055	2007	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
% positive samples/month	% positive samples/month: Percent of samples taken monthly that were positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

**For more information please contact:**

Tom Riggs, Water Operations Supervisor  
City of Nampa Waterworks Division  
24 1st St S  
Nampa, ID 83651  
208.468.5860 (Phone) 208.465.2216 (Fax)  
www.nampawaterdivision.org