

**CITY OF NAMPA WATERWORKS
IOCs 2010**

ANALYSIS	MAXIMUM CONTAMINATE LEVELS (MCLs ARE IN MG/L)	RESULTS (IN MG/L)	DATE ANALYZED
ACIDITY	NONE	-129.10	February-10
ALKALINITY	NONE	126.93	February-10
ARSENIC	0.01	0.0047	February-10
BARIUM	2.0	0.07	February-10
CALCIUM	NONE	79.37	February-10
CADMIUM	0.005	0.0007	February-10
CHROMIUM	0.1	0.00	February-10
CORROSIVITY	NONE	11.62	February-10
FLOURIDE	4.0	0.67	February-10
HARDNESS	NONE		
LEAD	0.015	0.0003	February-10
MERCURY	0.002	0.000	February-10
NITRATE	10.0	0.99	February-10
SELENIUM	0.05	0.00	February-10
PH	10.0	7.673	February-10